BARRY GLASSMAN
HARFORD COUNTY EXECUTIVE

BILLY BONIFACE
DIRECTOR OF ADMINISTRATION

KAREN D. MYERS
DIRECTOR OF PROCUREMENT

DEPARTMENT OF PROCUREMENT

ADDENDUM NO. 2

BID NO. 16-080

Electrical Work for Harford County Government

Nov 16, 2015

Ladies and Gentlemen:

The purpose of this addendum is to provide clarification(s) to all prospective proposers.

Question No. 1: What service level will be required for the W&S electrical work?

Answer No. 1: For Clarification: Water and Sewer electrical service work will be up to 600 amps and 3000 volts.

Sincerely,

Daniel Guthrie, CPPB
Chief