BARRY GLASSMAN
HARFORD COUNTY EXECUTIVE

BILLY BONIFACE
DIRECTOR OF ADMINISTRATION

KAREN D. MYERS
DIRECTOR OF PROCUREMENT

DEPARTMENT OF PROCUREMENT

REQUEST FOR PROPOSAL FOR BID NO. 16-085

Pump/Motor/Mechanical Equipment Maintenance Service Contract

Nov 24, 2015

Ladies and Gentlemen:

The purpose of this addendum is to provide clarification(s) to all prospective proposers.

Question No. 1: Are vendors required to have boom trucks or can they rent them on an as need basis?

Answer No. 1: Yes, Unless it is a specialty (i.e. abnormal reach & weight) then its is allowable to rent. This will be case by case and mutually agreed upon.

Question No. 2: What size and weight capacity is expected to pick up crane?

Answer No. 2: Approximately 2500 lbs. or less.

Question No. 3: Is a Can Station considered a permit confined space?

Answer No. 3: Harford County W&S does not consider a 'can station/ a Confined Space unless normal operation is altered (i.e. exhaust fan not working, or piping leak on floor). Vendors/Bidders need to follow their own company safety policies and provide own permit, equipment, confined space meter, etc.as required.

Question No. 4: Do we need a Hot Welding Permit

Answer No. 4: Yes and HCG also completes one as well and contractor provides their own equipment and fire watch.

Question No. 5: Is there double time for Sundays, and Holidays?

Answer No. 5: No. the bid page states with-in that we pay only 1 1/2 times contract labor rate.

Question No. 6: How much notice will there be given upon call?

Answer No. 6: see explanations for service times in the bid document

Question No. 7: Will there be any control work if related to pump?

Answer No. 7: yes. It will be case by case as required or requested.

Question No. 8: What about disposable shop supplies such as degreasers, rags, cleaners, etc.?

Answer No. 8: these items are incidentals and should be included in hourly labor rate calculations.

Question No. 9: What if there are time constraints, How should the vendor provide backup invoice for part already in stock?

Answer No. 9: it must be documented as such and should be a minimum since we require replace parts to be from MFG. It will be case by case.

Sincerely,

Daniel Guthrie, CPPB
Chief

cc: Jim Hynes, Abingdon WTP