

BARRY GLASSMAN
HARFORD COUNTY EXECUTIVE

BILLY BONIFACE
DIRECTOR OF ADMINISTRATION



KAREN D. MYERS
DIRECTOR OF PROCUREMENT

DEPARTMENT OF PROCUREMENT

BID NO. 16-241

Underground Water Storage Tank, Jarrettsville Highways Washbay

ADDENDUM NO. 1

June 24, 2016

Ladies and Gentlemen:

The purpose of this addendum is to provide clarification(s) to all prospective proposers.

Question No. 1: I wanted to check on whether the underground tank will have a protective coating on the interior surfaces?

Answer No. 1: Underground Tank is to be FRP (fiberglass reinforced plastic) water tank as manufactured by Xerxes or approved equal. No post-production special coatings are required on the tank interior.

Sincerely,

Daniel Guthrie, CPPB
Procurement Agent III

cc: Scott Kearby, DPW

Maryland's New Center Of Opportunity

410.638.3550 | 410.879.2000 | TTY Maryland Relay 711 | www.harfordcountymd.gov

220 South Main Street, Bel Air, Maryland 21014

THIS DOCUMENT IS AVAILABLE IN ALTERNATIVE FORMAT UPON REQUEST