

BARRY GLASSMAN
HARFORD COUNTY EXECUTIVE

BILLY BONIFACE
DIRECTOR OF ADMINISTRATION



KAREN D. MYERS
DIRECTOR OF PROCUREMENT

**INVITATION FOR BIDS
BID NO. 16-275**

REPAIR AND RESURFACING OF BRIGHT OAKS DRIVE, ETC.

ADDENDUM NO. 1

June 27, 2016

Ladies and Gentlemen:

The purpose of this addendum is to provide clarification (s) to all prospective bidders.

PLEASE SEE THE ATTACHED PRE-BID MEETING MINUTES DATED JUNE 17, 2016 FOR YOUR REFERENCE.

Sincerely,

Aaron E. Hall
Procurement

AEH/kmd

cc: Tim Dorbit, DPW/Engineering

Maryland's New Center Of Opportunity

410.638.3550 | 410.879.2000 | TTY Maryland Relay 711 | www.harfordcountymd.gov

220 South Main Street, Bel Air, Maryland 21014

THIS DOCUMENT IS AVAILABLE IN ALTERNATIVE FORMAT UPON REQUEST

BARRY GLASSMAN
HARFORD COUNTY EXECUTIVE

BILLY BONIFACE
DIRECTOR OF ADMINISTRATION



JOSEPH J. SIEMEK, P.E.
ACTING DIRECTOR OF PUBLIC WORKS

DEPARTMENT OF PUBLIC WORKS
DIVISION OF HIGHWAYS AND STORMWATER MANAGEMENT

June 17, 2016

Harford County Bid No. 16-275
Repair and Resurfacing of: Bright Oaks Drive, etc.

Pre-Bid Meeting Minutes

A pre-bid meeting was held on Friday, June 17, 2016 at 10:00 a.m. in the third floor conference room of the Department of Public Works at 212 S. Bond Street, Bel Air, Maryland 21014. Those in attendance were informed of the following:

1. Harford County stated the contents of the contract and scope of work. Those in attendance were informed that the bids are due in the Procurement Department by Wednesday, June 29, 2016 by 1:00 p.m. Bids are opened that day at 1:30 p.m. Questions for this bid should be emailed to Aaron Hall and are due by Wednesday, June 22, 2016. Questions and responses will be posted as an addendum on the bid board. There is a pre-qualification for this bid; you must be pre-qualified in A-2 Bituminous. Completion time is (45) forty-five working days from the notice to proceed. Liquidated damages are \$1000.00 per day.

This contract is a $\frac{3}{4}$ " warm mix of virgin material overlay for preventative maintenance, included are six roads that require 1 $\frac{1}{2}$ mill & fill using Superpave Asphalt Mix 9.5mm surface PG 64S-22 Level 1 and construction of sidewalk on Red Pump Road at MD. Route 24.

A contractor brought up the following issue:

- Can the County clarify the curb tie in for the $\frac{3}{4}$ " mix?

MARYLAND'S NEW CENTER OF OPPORTUNITY

410.638.3285 | 410.879.2000 | TTY Maryland Relay 711 | www.harfordcountymd.gov

212 South Bond Street, Bel Air, Maryland 21014

THIS DOCUMENT IS AVAILABLE IN ALTERNATIVE FORMAT UPON REQUEST

The ¾" overlay will butt against any extruded curb but must meet flush with any curb that has a concrete gutter pan. Please refer to pavement edge on page 3-10.

Submitted by,



Timothy G. Dorbit
Engineering Associate

TGD/ tgd

File: G:\Roads\BID CONTRACTS\16-275 - Bright Oaks Drive, Etc\2016 06 17 - Pre-Bid Meeting Minutes.docx